



**TECHNICAL STANDARDS
and SAFETY AUTHORITY**

345 Carlingview Drive
Toronto, Ontario M9W 6N9
Toll free 1-877-682-8772
www.tssa.org

Inspection Report

Work Order # 8334253

Inspection Report # 10100823

Inspection Address: 4300 BINBROOK RD BINBROOK ON L0R 1C0 Canada	Reference Number(s): 64780238	Inspection Completion Date: Aug 28, 2023
	Device Type: Passenger Elevator	Equipment Type: ED Elevator
Customer Name and Address: CITY OF HAMILTON 28 JAMES ST N 5TH FLOOR HAMILTON ON L8R 2K1 Canada	Task Type: ED Periodic Inspection	
	The facility/equipment is inspected in accordance with Ontario's Technical Standards & Safety Act and the appropriate regulations and codes. When an Inspector's order is issued, time limits for compliance reflect the severity of the violation and serve to avoid disruption of service.	

Inspection report delivered by email

INSPECTION NOTES

Inspection Order(s) are issued pursuant to my authority under section 21. (1) of the Technical Standards and Safety Act, 2000.

Where inspection orders are issued, TSSA will perform a follow-up inspection to confirm compliance. The responsible party is expected to make all the necessary corrections within the compliance time specified.

Where safety tasks are issued, TSSA will not perform a follow-up inspection to confirm compliance. The responsible party is expected to make all the necessary corrections within the compliance time specified. Safety tasks may be subject to a TSSA audit inspection and/or the responsible party may be required to confirm compliance to obtain your authorization/license.

TSSA has completed an inspection of this device. Failure to comply with inspection orders by the required date may result in this device being removed from service.

INSPECTION ORDER(S) and/or SAFETY TASK(S) ISSUED TO: CITY OF HAMILTON

EMAIL RECIPIENTS fmcpcpliance@hamilton.ca tssa.swontario@ca.schindler.com, HFacilities@hamilton.ca

No.	Inspection Order(s)	Issued Date	Compliance Date
	Inspection order(s) with follow-up (high risk order)		
1.	The overdue category 1 [annual] periodic task for means to restrict hoistway or car door opening (CAD 8.6.4.19.16) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Sep 11, 2023

No.	Safety Tasks	Issued Date	Compliance Date
1.	ONTARIO REGULATION 209/01. (ELEVATING DEVICES) 12	Sep 07, 2023	Aug 28, 2023

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.
(Note: This is not an invoice)

Putting Public Safety First



Work Order # 8334253

Inspection Report # 10100823

	<p>- Operation prohibited without license No owner shall operate an elevating device or permit it to be operated unless it is licensed and it complies with this Regulation, the code adoption document and any applicable director's order. O. Reg. 252/08, s. 7.</p> <p>MAINTENANCE</p> <p>MAINTENANCE LOG SHOWS 12 VISITS PER YEAR SCHEDULED. ONLY 4 VISITS PERFORMED THIS YEAR.</p>		
2.	The overdue category 1 [annual] periodic task for power operation of door system (CAD 8.6.5.14.6) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023
3.	The overdue category 1 [annual] periodic task for power operation of door system (CAD 8.6.4.19.8) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023
4.	The overdue category 1 [annual] periodic task for relief valve verification of setting and system pressure test(CAD 8.6.5.14.1) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023
5.	The overdue category 1 [annual] periodic task for emergency communications (CAD 8.6.4.19.15) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023
6.	The overdue category 1 [annual] periodic task for normal and final terminal stopping devices (CAD 8.6.4.19.5) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023
7.	The overdue category 1 [annual] periodic task for firefighter's emergency operation (CAD 8.6.4.19.6) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023
8.	The overdue scheduled maintenance task for anticreep and low oil protection (CAD 8.6.5.12) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023
9.	The overdue category 1 [annual] periodic task for hydraulic cylinders and pressure testing (CAD 8.6.5.14.2) shall be performed and the log book signed to confirm compliance.	Sep 07, 2023	Nov 26, 2023

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.
(Note: This is not an invoice)



**TECHNICAL STANDARDS
and SAFETY AUTHORITY**

345 Carlingview Drive
Toronto, Ontario M9W 6N9
Toll free 1-877-682-8772
www.tssa.org

Inspection Report

Work Order # 8334253

Inspection Report # 10100823

This report is issued under the *Technical Standards and Safety Authority Act, 2000, s. 17(1)*

17. (1) An inspector may conduct an inspection and may, as part of that inspection, enter and inspect at any reasonable time the lands and premises where any of the things, parts of the things or classes of things to which this Act, the regulations or a Minister's order apply are used, operated, installed, made, manufactured, repaired, renovated or offered for sale for the purpose of,
(a) ensuring compliance with this Act, the regulations or Minister's order;
(b) ensuring that an authorization holder remains entitled to the authorization; or
(c) determining whether a hazardous condition exists. 2006, c. 34, s. 25 (5)

Customer Signature & Position / Date:		Inspector Name: Les Simonffy	Inspector Contact Number: +1 905-741-7825
Report Received By:	Customer Contact Number:	Inspector Email: lsimonffy@tssa.org	

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.
(Note: This is not an invoice)

Putting Public Safety First