

Birch Avenue Municipal Class EA

Drainage and Stormwater Management Report



Prepared for the City of Hamilton
by IBI Group
January 20, 2020

Table of Contents

1	Introduction	1
2	Study Scope	1
3	Background Information	3
4	Site Description	4
4.1	Existing Land Use, Soils, Groundwater and, Physiography	4
4.2	Existing Drainage Conditions	4
4.3	Existing Drainage Elements	8
4.3.1	Storm Relief Sewer	8
4.3.2	Combined Sewer	8
4.3.3	Sanitary Sewer	9
5	Flooding Issues	9
6	Birch Avenue Improvements	10
7	Hydrologic Analysis	11
7.1	Hydrologic Analysis Using PCSWMM Model	11
7.1.1	Modeling Overview	11
7.1.2	Hydrology	12
7.2	Birch Avenue Existing Sewer Capacity	13
8	Drainage Design Options	14
8.1	Road Improvement Options	14
8.2	Potential Peak Flow Reduction Measures	15
8.3	Pumping Stations	20
8.4	Storm Drainage Pumping System	21
8.5	Heating and Ventilation System	21
8.6	Dewatering Costs	24
9	Conclusions and Recommendations	24

List of Figures

Figure 1: Key Plan	2
Figure 2: The Location of Railway Bridges	3
Figure 3: Catchment Area Map for Major System	6
Figure 4: Catchment Area Map for Minor System	7
Figure 5: The Location of Manhole HJ07E045	9
Figure 6: Lake Ontario Average Water Levels	10
Figure 7: PCSWMM Model Layout	12
Figure 8: Proposed Flow Diversion at Princess Street toward Sherman Avenue	19

List of Tables

Table 1: Summary of Peak Flows by PCSWMM Model	13
Table 2: Conveyance Capacity of Existing Storm Relief Sewer	13
Table 3: Road Lowering for the Bridge Clearance at South and North Underpasses	14
Table 4: Analysis of Alternatives	16
Table 5: Storm Sewer Flow Conveyance Improvements	18
Table 6: Optional Pump Rates	21
Table 7: Alternative Remedial Measures to Reduce Pumping	22
Table 8: Pumping Station Details	23

List of Appendices

Appendix A – Existing Condition Drawing	
Appendix B – Typical Cross-Sections	
Appendix C – Proposed Condition Drawing	
Appendix D – The SCS Type II 6 Hour Hyetograph	
Appendix E – Proposed Condition Drawing (Option 2 & 3)	
Appendix F – Pump Station Equipment Layout	
Appendix G – Generator Sizing	
Appendix H – Dewatering Costs	

1 Introduction

The City of Hamilton is undertaking a Municipal Class Environmental Assessment (MCEA) for the proposed improvements to Birch Avenue from Burlington Street East to Barton Street East. IBI Group has been retained by the City of Hamilton to complete a Schedule “B” EA under the Municipal Class EA (MCEA) process for the proposed improvements to Birch Avenue. The project limits are illustrated in **Figure 1**.

The City of Hamilton is undertaking the construction of the Hamilton Transit Maintenance and Storage Facility (MSF) at 80 Brant Street (with access off of Birch Avenue). Through the construction of this facility, changes will have to be made to Birch Avenue to accommodate the new user demands.

The stretch of Birch Avenue (between Burlington Street East and Barton Street East) currently has three lanes in one direction and has three rail bridges (Bridges 330, 331, and 332). To accommodate for transit vehicles, the road will be converted to two-way. **Figure 2** provides the location of three bridges.

Changes in engineering standards, pertaining to road clearance under bridges, have made the bridges no longer compliant. Bridge 331 will be removed; however, a recommendation will be made through this EA study to address clearance issues under Bridges 330 and 332. The bridge clearance options of lowering the road will create challenges regarding stormwater management.

This Stormwater Management (SWM) Report is a supporting document to the Class EA for the proposed improvements to Birch Avenue. It serves to summarize the existing drainage conditions and proposed drainage and SWM Plan to mitigate the existing drainage issues along the Birch Avenue corridor. The overall focus of the study is to achieve a 2-year level of service for Birch Avenue between Barton Street East and Burlington Street East.

2 Study Scope

The following describes the tasks covered in the study to meet the stormwater management challenges identified for the preferred solution:

1. Delineate drainage area at the underpasses where bridges are located;
2. Establish design stormwater runoff rates;
3. Concepts to minimize runoff volume to be managed (minimizing drainage catchment, infiltration/diversion opportunities such as Low Impact Development technologies, etc.);
4. Establish required hydraulic capacity of pump station alternatives;
5. Forcemain route option;
6. Outfall/discharge location options, including combined sewer versus discharge to harbor;
7. Identify land/footprint requirements for stormwater infrastructure;
8. Pumping station and generator location options and property needs;
9. Wet well configuration, and
10. Constructability, maintenance/repair access, and cost of alternatives.

593500


594000

594500

595000

595500


596000



BIRCH AVENUE



No.	REVISIONS	INITIAL	DATE	REFERENCE MATERIALS	ACTIVITIES



IBI
 IBI GROUP
 100-175 Galaxy Boulevard
 Toronto ON M9W 0C9
 Canada
 tel 416 679 1930
 fax 416 675 4620
 ibigroup.com

Project Manager

 Design Manager



BIRCH AVENUE
 Key Plan
 Figure- 1



Figure 2: The Location of Railway Bridges

3 Background Information

Previous studies and reports related to hydrology, hydraulics, stormwater management, and adjacent development plans were obtained from the City of Hamilton and reviewed, and are listed below:

- City of Hamilton, Stormwater Master Plan – Class Environmental Assessment Report (City-Wide), Prepared by Aquafor Beech Limited, May 2007
- Birch Avenue Stormwater Modelling and Flood Relief Study Report, City of Hamilton, prepared by McCormick Rankin, April 2013
- Technical Memo on Birch Avenue Sewer Capacity Analysis, prepared by GM BluePlan Engineering, February 2, 2017

- Draft Report for Flooding and Drainage Master Servicing Study, City of Hamilton, prepared by Aquafor Beech Limited, June 7, 2019
- Geotechnical Investigation Report for Proposed Watermain, Birch Street, Hamilton, Ontario, Prepared by Terraprobe, April 13, 1997
- City of Hamilton, Geotechnical Investigation Report for Proposed Road Reconstruction and Watermain Replacement, Birch Avenue, Hamilton, ON, Prepared by EXP Services Inc., dated November 13, 2018

4 Site Description

Within the project limits, Birch Avenue is principally a three-lane one-way urban arterial road with an additional turning lane at the intersection of Barton Street East. The existing right-of-way (ROW) generally varies from 13.0 m to 19.5 m. Sidewalk is available mostly on the east side of Birch Avenue. However, from the intersection of Barton Street East to approximately 415 m north, sidewalks are available on both sides of Birch Avenue. Birch Avenue is a straight roadway throughout the study corridor and follows a relatively flat topography. The topography within the project limits rises slightly toward the south and gently undulates at three low/sag points located at the railway crossings.

Given the urban context of the study area, natural heritage features are generally limited to ornamental plantings, manicured lawns, and grassed strips.

Within the project limits, there are no aquatic features (watercourses) or areas that would be designated as Areas of Natural and Scientific Interest (ANSI), Environmentally Sensitive Areas (ESA), or Provincially Significant Wetlands (PSW). Currently, there are three railway underpasses that exist on Birch Avenue between Princess Street and Burlington Street East.

4.1 Existing Land Use, Soils, Groundwater and, Physiography

The Birch Avenue study area primarily consists of industrial landuse; there is a steel factory along the east side, a City Works yard to the west (between Princess Street and Brant Street), and a hydro corridor adjacent to Birch Avenue on the west side.

The site is located within the Iroquois Plain physiographic region of Southern Ontario which stretches along the eastern and the southern shores of western Lake Ontario. The site is also situated within the former Sherman Inlet. In the early twentieth century, fill was imported from off-site sources to fill the Sherman Inlet and associated wetland. The results of the geotechnical investigation report "Geotechnical Investigation, Proposed Watermain, Birch Street, Hamilton, Ontario, prepared by Terraprobe, dated April 13, 1997, revealed that the depth of fill in the boreholes ranged from 0.6 m to 1.2 m along Birch Avenue. Organic silt to silty clay material present beneath the fill.

The groundwater levels measured in the open boreholes immediately following the drilling ranged from about 1 m to 3 m below the existing ground surface as reported in the above referenced Geotechnical Investigation report.

4.2 Existing Drainage Conditions

The study area falls within the Urban Hamilton watershed as shown on the Hamilton Conservation Authority's watershed map. Drainage within the study area is principally influenced by topography, land cover, and grade changes along Birch Avenue. Within the project limit, Birch Avenue is a three-lane one-way urban roadway section with curbs, gutters, and pedestrian sidewalks. Stormwater resulting from minor storm events is conveyed by trunk storm relief sewer and discharged to Lake Ontario through the outlet

located north of Burlington Street East. Major system flows within the roadway corridor are conveyed to existing outlets as roadway overland flow.

The Birch Avenue study area is situated primarily on an overland flow route. There are existing drainage and flooding issues along Birch Avenue. These issues include: large external drainage areas that contribute flows to the storm trunk relief sewer; external major overland flow through Birch Avenue; the invert elevation of the storm trunk relief sewer; and, the hydraulic effect of the Lake Ontario water levels on the sewer performance. The study area is located within the City's combined sewer servicing catchment area, and the storm relief sewer on Birch Avenue receives combined sewer overflows at different spots, including at the overflow location at Princess Street.


A review of topographic maps and the Digital Elevation Model (DEM) (provided by the City of Hamilton) was conducted and external catchment areas for each of the bridge underpasses were delineated for major and minor system flows. The catchment area map for the major system is shown on **Figure 3**. The catchment area is completely urbanized and serviced by combined and partially separated sewers.

The Birch Avenue trunk storm relief sewer extends from King Street (140 m west of Sherman Avenue), north on Sherman Avenue to Barton Street, west on Barton Street to Birch Avenue and north on Birch Avenue to the outlet located north of Burlington Street East. There are also storm sewer legs which extend west along Beechwood Avenue and Rosemont Avenue. The eastern sewer legs collect a significant amount of flow from the primary overland flow route which passes through residential properties between Sherman Avenue and Barnesdale Avenue. The catchment area map for minor system including storm sewer networks is presented on **Figure 4**.

There are no watercourses documented or observed during site investigations within the study area, so consequently there are no watercourse crossings within the drainage scope of work for the Birch Avenue improvements.

DWG. No. 001 presented in **Appendix A** depicts the existing condition drainage within the project limits, including existing infrastructure and landscaping, drainage area discretization, outlets, and the direction of overland flow routes.

BIRCH AVENUE CATCHMENT AREA



Legend

- - - MAJOR SYSTEM CATCHMENT
- ROAD EDGE
- CONTOUR
- SEWER NETWORK
- STORM
- COMBINED
- SANITARY
- OVERLAND FLOW
- C1 CATCHMENT NO
- 28.3 0.75 RUN OF COEFFICIENT AREA(Ha.)

No.	REVISIONS	INITIAL	DATE	REFERENCE MATERIALS	ACTIVITIES




IBI
 IBI GROUP
 100-75 Galaxy Boulevard
 Toronto ON M9W 0C9
 Canada
 tel 416 679 1930
 fax 416 679 8620
 ibigroup.com

Project Manager
 Design Manager



BIRCH AVENUE
 MAJOR CATCHMENT AREA
 Figure-3



Legend

- MINOR SYSTEM CATCHMENT
- ROAD EDGE
- CONTOUR
- SEWER_NETWORK
- STORM
- COMBINED
- SANITARY
- ➔ OVERLAND FLOW CATCHMENT NO
- C1
28.3/0.75 RUN OF COEFFICIENT
- AREA(Ha.)

No.	REVISIONS	INITIAL	DATE	REFERENCE MATERIALS	ACTIVITIES



IBI
 IBI GROUP
 100-75 Galaxy Boulevard
 Toronto ON M5V 0C9
 Canada
 Tel: 416 679 1930
 Fax: 416 679 4620
 ibigroup.com

Project Manager
 Design Manager



BIRCH AVENUE
 MINOR CATCHMENT AREA
 Figure-4

4.3 Existing Drainage Elements

4.3.1 Storm Relief Sewer

Under existing conditions, runoff from Birch Avenue is primarily collected by catchbasins, conveyed by storm relief sewers, and finally discharged into Lake Ontario through the outlet located north of Burlington Street East.

The existing storm relief sewer along Birch Avenue is a concrete structure with the size of 1450 mm X 1800 mm, located under the sidewalk on the east side of Birch Avenue between Burlington Street East and Princess Street. On the south side of Princess Street along Birch Avenue, the size of the storm relief sewer changes to 1200 mm X 1550 mm. The slope of the storm relief sewer along Birch Avenue between Barton Street East and Burlington Street East varies from 0.05% to 0.4%. These low gradients reduce the sewer capacity significantly. The obvert of the sewer is above the road elevation, particularly within the road sags at the railway underpasses. The storm relief sewer is integral to the footings of each of the three railway bridge abutments.

4.3.2 Combined Sewer

The catchment area, located south of Princess Street, is serviced by the existing combined sewer system. The existing sewer along Birch Avenue also has a combined sewer which varies in size and gradient. The combined sewer between Wilson Street and Princess Street has a 600 mm X 900 mm non-circular section and the slope varies from 0.3% to 0.6%. Between Barton Street East and Princess Street, there is a parallel storm relief trunk sewer (1200 mm X 1314 mm) in addition to the 600 mm X 900 mm combined sewer. The storm relief sewer flows north towards Burlington Street East, while the combined sewer (600 mm X 900 mm) connects to the Princess Street combined sewer system and continues to flow east.

The combined sewer networks, located at the intersection of Birch Avenue and Princess Street, discharge wet weather flow into the Birch Avenue storm relief sewer through an overflow chamber located at the intersection of Birch Avenue and Princess Street. The low flow (sanitary flow) is conveyed east along Princess Street, through the combined sewer system. As a result, the storm and sanitary sewer system are completely separate along Birch Avenue from Princess Street to the outfall located north of Burlington Street East.

Princess Street intersection improvements were completed near Manhole HJ07E045 to prevent inflow of dry weather flow into the Birch storm trunk relief sewer by reinstalling an overflow weir. The location of the manhole is provided in **Figure 5**.




Figure 5: The Location of Manhole HJ07E045

4.3.3 Sanitary Sewer

There is an existing sanitary sewer that runs north along Birch Avenue to service Birch Avenue adjacent areas. This sanitary sewer starts at the railway crossing interchange located just north of Princess Street, continues north, and discharges into the Burlington Street East sanitary sewer system. The sanitary sewer size varies from 300 mm to 450 mm and the slope varies from 0.19% to 0.57%.

5 Flooding Issues

As mentioned previously, there are three low/sag points located along Birch Avenue at the three railway underpasses. The slope of the existing storm relief sewer along Birch Avenue, between Barton Street East and Burlington Street East, varies from 0.05% to 0.4%. These low gradients reduce the sewer capacity significantly. Therefore, it is well recognized that the capacity of the existing storm sewer on Birch Avenue is not adequate to convey the required design flows. This inadequate flow capacity of the storm sewer results in undesirable flooding and level of service at the three railway underpasses. Also, the obvert of the storm relief sewer at some locations is above the road elevation, particularly within the low/sag points at the railway underpasses.

Another significant factor for flooding, associated with the Birch Avenue storm relief sewer and roadway, is the level of Lake Ontario and its hydraulic effect on the sewer's outlet. Summer average lake level is approximately 75.0 m as shown in **Figure 6**. The top of road elevations at the railway underpass sags are 75.69 m, 76.0 m, and 76.40 m for the north, middle, and south railway crossings, respectively. The sewer inverts range between 74.29 m at Burlington Street East, 75.0 m just north of south railway underpass, 75.20 m at Princess Street, and 76.29 m at Barton Street. Therefore, the sewer invert is typically wet up to just north of the south railway underpass.




Figure 6: Lake Ontario Average Water Levels

6 Birch Avenue Improvements

A new Bus Maintenance and Storage Facility (MSF) is planned at Birch Avenue and Brant Street, and the City desires improvements to active transportation along the corridor. The Birch Avenue improvements, as part of this project, will include incorporating a multi-use path on the west side of Birch Avenue between Princess Street and Burlington Street East. The proposed improvement also includes localized intersection improvements along the entire corridor. Existing catchbasins will require minor adjustments or relocation where curb lines are to be shifted as part of the proposed design. The shift to two-way operations from Burlington Street East to Barton Street East provides the opportunity to address two existing issues along the corridor – low clearance at two railway crossing bridges and drainage issues. Both of these pose safety issues to road users and may impact the operation of the proposed MSF in adverse conditions.

The existing railway bridge located south of Brant Street is proposed to be removed and the low point located at this crossing will be improved to provide a positive roadway drainage for this location. Due to the low clearance at the existing south and north railway crossing bridges, the Birch Avenue road profile at those railway crossing locations is proposed to be lowered to increase the existing traffic clearance. **Appendix B** includes typical cross-

sections which represent the proposed condition. In general, the proposed changes to the existing cross-section will have little impact to the overall pavement area and are not expected to significantly impact drainage along Birch Avenue within the project limits.

7 Hydrologic Analysis

A detailed hydrologic analysis was conducted to determine the peak flow rates for both minor and major storm events at the Birch Avenue low/sag points located at the two railway crossing locations (Bridge 332 and Bridge 330). The peak flow rates were determined using a PCSWMM model. The following sections provide a brief description of the hydrologic methods that are used for the flow calculations.

DWG. No. 002A, presented in **Appendix C**, depicts the proposed condition within the project limits, drainage area discretization, outlets, and the direction of overland flow routes. The existing internal and external catchment areas have been maintained in the proposed condition, as well as the existing outlet and drainage patterns.

7.1 Hydrologic Analysis Using PCSWMM Model

A dual drainage model was developed for Birch Avenue using PCSWMM to assess the performance of the existing major and minor drainage systems. It includes the sewer system (minor system designed for smaller storm events), the overland flow paths (major system for higher storm events), and the connection (manholes and catch basins) between the two systems. PCSWMM has the ability to carry out design and analysis of (i) new, (ii) existing, and (iii) combined new and old urban drainage systems where surface flows are routed over the land surface (major system, such as roads, swales, street sags, and storage areas) while part of the runoff simultaneously flows in the underground conveyances (minor system, such as sewer pipes and associated infrastructure).

7.1.1 Modeling Overview

The minor system's performance was assessed based on maximum hydraulic grade line in the sewer, and percent pipe full capacity. The major system was evaluated on the basis of ponding depths / extents, and flooding frequency.

The hydraulic and hydrologic data were collected and compiled into suitable formats, and were used to build the dual drainage system. The major system was then created parallel to the minor system. The major systems were assigned the road cross-sections at various points in accordance with as-built drawings and topography.

Overall, the dual drainage model boundary starts from Barton Street East and extends to Burlington Street East covering a 114.46 ha area, which consists of 172 sub-catchments, 71 conduits (including major and minor sewers and roads) and 73 junctions (manholes). The model layout is presented in **Figure 7**.




Figure 7: PCSWMM Model Layout

7.1.2 Hydrology

Surface hydrology includes determination of the flow rate, runoff volume, and timing (hydrograph) for a sub-catchment area by considering various factors, such as expected rainfall intensity (hyetograph), existing land use, sub-catchment delineation, infiltration, depression storage, Manning's roughness for pervious and impervious areas, percent directly connected impervious areas, and flow path length.

The City of Hamilton prescribed SCS Type II, 6 hour duration hyetograph for Mount Hope station to be used as design storm for computing runoff flow rates. The hyetograph is shown in **Appendix D**.

The average imperviousness of each sub-catchment was calculated as an area-weighted average. The different land uses in GIS data were reviewed against the aerial photo to confirm the percent impervious.

Based on different land use types, Manning's roughness coefficient of 0.013 was assigned to represent the concrete surface of road pavement and sewers. Manning's roughness coefficient of 0.24 was applied for pervious area, such as park and open space.

Typical depression storage values of 2.5mm and 5mm were assumed for impervious and pervious areas, respectively. The Horton Infiltration method was used to simulate infiltration in the model.

The dual drainage model was run for all storm events up-to the 100-year storm events. A summary of peak flows for different storm events at the two railway crossing locations are presented in **Table 1**.

Table 1: Summary of Peak Flows by PCSWMM Model

ANALYSIS POINT	TOTAL AREA (HA)	STORM EVENT	EXISTING STORM SEWER PEAK FLOW (M ³ /SEC)	OVERLAND PEAK FLOW (M ³ /SEC)	TOTAL FLOW (M ³ /SEC)
South Railway Crossing (332)	80.18	2-Year	4.29	0.28	4.57
		5-Year	5.05	0.33	5.38
		10-Year	5.08	0.34	5.42
		25-Year	5.14	0.34	5.48
		50-Year	5.17	0.34	5.51
		100-Year	5.19	0.33	5.52
North Railway Crossing (330)	112.12	2-Year	3.55	1.14	4.69
		5-Year	3.87	2.25	6.12
		10-Year	4.06	2.51	6.57
		25-Year	4.21	2.67	6.88
		50-Year	4.31	2.71	7.02
		100-Year	4.39	2.70	7.09

7.2 Birch Avenue Existing Sewer Capacity

As mentioned previously, the existing storm relief sewer along Birch Avenue is a concrete box section with varying size and slopes. The PCSWMM model provided maximum flow conveyance capacity of the storm relief sewer and is presented in following **Table 2**.

Table 2: Conveyance Capacity of Existing Storm Relief Sewer

LOCATION	SEWER SIZE (MM X MM)	SLOPE (%)	FLOW CONVEYANCE CAPACITY (M ³ /SEC)
Between Barton Street and Princess Street	1200 X 1550	0.4	3.66
Between Princess Street and Brant Street	1450 X 1800	0.4	4.28
	1450 X 1800	0.1	3.28
	1450 X 1800	0.08	3.03
Between Brant Street and North Railway Crossing	1450 X 1800	0.18	3.45
Between North Railway Crossing and Burlington Street East	1875 X 1800	0.05	3.63

As seen in **Table 2** above, the existing storm relief sewer has different flow conveyance capacity depending on the corresponding size and slope of the storm sewer. The minimum

flow conveyance capacity of 3.03 m³/sec has occurred between Princess Street and Brant Street. Therefore, the existing storm relief sewer along Birch Avenue does not have enough conveyance capacity to convey 2-year storm flow at certain locations within the study area.

8 Drainage Design Options

The current flooding, due to major and minor storm events at the underpasses and adjacent roadway areas, will further be impacted by the proposed road improvements.

8.1 Road Improvement Options

The proposed roadway improvements will change Birch Avenue from a one-way to a two-way road and will improve the active transportation facilities along the corridor. If the existing roadway profile and low clearance at the two railway crossing locations are maintained, these will remain posing safety issues to road users and may impact the operation of the proposed MSF.

Lowering the Road at Two Railway Underpass

The proposed Birch Avenue road improvements will require lowering the road profile to provide adequate bridge clearances at the south and north underpasses. The following road lowering options are being considered at the two underpasses:

Option 1: Maintain Existing Condition

Option 2: Lowering Road by 0.3 m

Option 3: Lowering Road by 0.6 m

Table 3: Road Lowering for the Bridge Clearance at South and North Underpasses

LOCATION	STORM EVENT	FLOODING DEPTH (M)		
		Option 1: (Maintain Existing Condition)	Option 2: (Lowering Road by 0.3m)	Option 3: (Lowering Road by 0.6m)
South Railway Crossing (332)	2-Year	0.53	0.68	0.83
	5-Year	0.53	0.69	0.83
North Railway Crossing (330)	2-Year	0.72	0.85	0.97
	5-Year	1.02	1.16	1.30

The above options of profile-lowering will significantly increase the flooding depth at both underpasses. **Table 3** provides impacts on flooding depths resulting from the three options.

The obvert of the storm relief sewer is approximately 500 mm and 400 mm above the road surface at the south and north railway crossings, respectively, and therefore significantly above the road at the two railway underpasses.

The most significant factor for flooding associated with the Birch Avenue storm relief sewer and roadway is the level of Lake Ontario and its hydraulic effect on the sewer's outlet. Summer average lake level is approximately 75.0 m as shown in **Figure 6**. The top-of-road elevations at the railway underpass sags are 75.69 m and 76.40 m for the north and south railway crossings, respectively. The existing middle underpass is not discussed in this

report as the City has confirmed that the railway crossing will be removed and the sag will be eliminated.

With the lowering of the road, it will not be possible to capture and discharge all major flows solely through a gravity sewer. The lowering of the road profile below the Lake Ontario water level will make storm pumping inevitable. The sewer inverts range between 74.29 m at Burlington Street East, 75.0 m just north of the south railway underpass, 75.20 m at Princess Street, and 76.29 m at Barton Street. Therefore, the sewer invert is typically wet up to just north of the south railway underpass.

A 2-year level of protection is targeted for the storm system. This would provide emergency vehicle access during the 2-year design storm (The MTO Highway Drainage Design Standards, January 2008, SD-7 for Depressed Roadways and Underpasses indicates that the maximum depth of flooding in a road sag should be 30 cm measured from the crown of the roadway to ensure that emergency vehicles can access or traverse a depressed roadway).

The analysis of alternatives is provided in **Table 4** where each of the alternatives is summarized and includes the following information:

- Road lowering options (the alternatives considered);
- Flooding depth;
- Level of service;
- Pumping;
- Constructability;
- Drainage/pumping outlet;
- Impact on existing storm sewer and,
- Road lowering preference.

Based on the above analysis of alternatives, the preferred alternative is to lower the road between 0.3m and 0.6m so as to achieve the desired bridge clearance.

8.2 Potential Peak Flow Reduction Measures

A number of potential peak flow reduction measures were considered in order to reduce the underpass pumping rates required to address flooding on Birch Avenue. A description of each measure is described below.

1. “Do Nothing” Alternative

If the existing roadway profile and low clearance at the two railway crossing locations are maintained, these will remain posing safety issues to road users and may impact the operation of the MSF. Since there are potential negative consequences associated with the “Do Nothing” alternative it cannot be considered a reasonable or acceptable course of action.

2. Low Impact Development (LID) Measures

This measure includes the provision of an underground infiltration system upstream of the south and north underpasses. The current catchbasins upstream of the south underpass (Bridge No. 332), located along the west curb line of Birch Avenue, will be disconnected

Table 4: Analysis of Alternatives
Birch Avenue Municipal Class Environmental Assessment
Drainage and Stormwater

Alternative ID	Flooding Depth	Level of Service	No of Railroad Crossings	Pumping*	Constructability/Property*	Secondary Benefit of Pumping	Outlet to Harbour	Existing Storm	Preference
Maintain As Is (Do Nothing)	<u>Max Flood Depth at South Underpass, 332:</u> 2-year: 0.53 m 5-year: 0.53 m <u>Max Flood Depth at North Underpass, 330:</u> 2-year: 0.72 m 5-year: 1.02 m	Less than 2-year level of service.	3 Underpasses.	No. South sag: 76.40m North sag: 75.69m Lake: 75.0m	-	-	-	Exposed by 0.5 m	-
Lower Road Profile by 0.30m (Provide 0.3 m additional clearance to bridge, construct pumping station, provide LID underneath 3 m wide MUP.)	<u>Max Flood Depth at South Underpass, 332:</u> 2-year: 0.68 m 5-year: 0.69 m <u>Max Flood Depth at North Underpass, 330:</u> 2-year: 0.85 m 5-year: 1.16 m	2-year level of service. 2 year-flood frequency moderate (50% chance any given year).	2 Underpasses (crossing 331 will be eliminated).	Yes. South sag: 76.10m North sag: 75.39m Lake: 75.0m	Property required, pumping station, 1 km long forcemain and access to pump house	Provides relief to upstream areas.	No, existing can be utilized.	Exposed by 0.8 m	Preferred: underpass elevations are still above lake levels, exposed sewer depth is lesser, frequent pumping is avoidable, & will not require backwater flow preventer.
Lower Road Profile by 0.60 m (Provide 0.6 m additional clearance to bridge, construct pumping station, provide LID underneath 3 m wide MUP.)	<u>Max Flood Depth at South Underpass, 332:</u> 2-year: 0.83 m 5-year: 0.83 m <u>Max Flood Depth at North Underpass, 330:</u> 2-year: 0.97 m 5-year: 1.30 m	2-year level of service. 2 year-flood frequency moderate (50% chance any given year).	2 Underpasses (crossing 331 will be eliminated).	Yes. South sag: 75.80m North sag: 75.09m Lake: 75.0m North sag will go lower than the recorded highs of the Lake.	Property required, pumping station, 1 km long forcemain, access to pump house, and backwater flow preventor	Provides relief to upstream areas.	No, existing can be utilized.	Exposed by 1.1 m	Not preferred: Underpass elevations are below recorded highs in the Lake, frequent pumping required, exposed sewer depth is higher, & will require backwater flow preventer.
Lower Road Profile by 1.3m (Provide 0.6 m additional clearance to bridge, construct pumping station, provide LID underneath 3 m wide MUP.)	<u>Max Flood Depth at South Underpass, 332:</u> 2-year: 1.13 m 5-year: 1.13 m <u>Max Flood Depth at North Underpass, 330:</u> 2-year: 0.70 m 5-year: 1.01 m	-	-	South sag: 75.10m North sag: 74.39m Lake: 75.0m North sag will be lower than the normal lake level. Both will be lower than the recorded highs of the Lake.	-	-	-	Exposed by 1.8 m (entire storm trunk is exposed.)	Not Recommended.

Lowering road profile by 1.3m was not carried forward as it had significant impact on intersections and vertical curve.

The recorded water height levels in the Lake are more than 75.5 m in summer.

The size of the existing Storm Sewer is 1450 m (W)x 1800m (D).

The last leg of existing STM, d/s of Burlington St. and just u/s of Harbor outlet, has an additional capacity of 1.7m³/s.

Flooding Depths are more than 300 mm that makes pumping inevitable.

Birch Ave. Stormwater Modelling and Flood Relief Study, May 2013 recommended a combination of a new sewer along Sherman Ave. and divert Barton St. STM relief for Birch to Sherman Ave (Total Cost \$11m).

In option 3, catch basins at sags will not be able to drain to the existing STM (75.8-1.3=74.5m i.e. below the invert of exist STM 75.094m). This will result in frequent pumping.

*Refer to Table 7 of the SWM report

From the existing storm line and a combination of catchbasins and side-inlets is proposed to capture major flows conveyed along the west gutter of Birch Avenue. The intent is to capture maximum road flow by increasing inlet capacity and providing maximum storage volume in chambers; this will reduce peak flow through infiltration and attenuation, thus reducing the pumping requirement at the underpasses during the 2-year storm event. The design of the storage facility would reduce outflows to an acceptable peak flow to minimize the impact on the Birch Avenue trunk sewer downstream. This option would effectively reduce pumping requirements at both underpasses, thereby reducing pumping infrastructure costs. The proposed design will be able to divert a flow of 1.26 m³/sec to infiltration chambers.

The geotechnical investigation report “Geotechnical Investigation, Proposed Watermain, Birch Street, Hamilton, Ontario, prepared by Terraprobe, dated April 13, 1997”, revealed that the groundwater levels measured in the open boreholes, immediately following the drilling, ranged from about 1 m to 3 m below the existing ground surface. According to the above-referenced report, depth of fill in the boreholes ranged from 0.6 m to 1.2 m along Birch Avenue. Organic silt to silty clay material is present beneath the fill which has an approximate infiltration rate of 10 mm/hour (reference: <http://www.fao.org/3/S8684E/s8684e0a.htm>) and is suitable for implementation of the underground infiltration chambers within the project area.

The LID system is proposed from the south underpass to Burlington Street East. The infiltration chambers can be installed underneath the proposed 3 m wide multi-use path on the west side of Birch Avenue. The measure will reduce the amount of major overland flow that enters the underpasses and will reduce the pumping cost. The LID will provide some hydraulic benefits; however, it will not alleviate the underpass flooding completely.

The proposed LID measure will reduce the rates of runoff to the outlets and provide a high level of treatment through the capture of both particulate and dissolved constituents. These types of facilities reduce water temperature impacts and enhance groundwater recharge. The proposed chambers will provide 1500 m³ and 3400 m³ of storage at the south and north underpass locations respectively. The locations of the proposed infiltration chambers are shown on **DWG. No. 002A in Appendix C**.

Due to limited space availability in the hydro corridor, this alternative was deemed infeasible. A 15 m buffer of horizontal clearance is required around each Hydro One structure to preserve the work zone required for line maintenance and to ensure the geotechnical stability of the towers. In addition, any underground installations on the hydro corridor must be designed to withstand the loading conditions created by heavy maintenance vehicles that may be used by Hydro One. The 15 m buffer zones, relative to the hydro corridor boundary, reveal that the construction of a storm relief line/infiltration chambers within this hydro corridor is not feasible. As such, this option is not recommended and is not discussed further.

3. Increased Capacity along Existing Storm Sewer Alignment

An option to upgrade the existing Birch Avenue storm sewer to provide additional hydraulic capacity was assessed. Due to the physical constraints of the sewer's existing location, enlarging the sewer vertically (rise/height) was deemed infeasible for the following reasons:

- The average water level in Hamilton Harbour (Lake Ontario) is above the invert of the sewer throughout the majority of the study area. Therefore, lowering the sewer will not provide an appreciable increase in sewer capacity, and
- The obvert of the sewer is at the road surface from Burlington Street East to just north of the south railway underpass and significantly above the road sag elevations at the underpasses. As such, providing additional capacity above the existing sewer will not benefit the surface flooding problem on Birch Avenue.

The concrete box sewer size can be increased horizontally (width); however, this will involve changes to the current road cross-section at the underpasses. The east wall of the sewer forms an integral part of the overhead railway bridge abutments. Increasing the width of the sewer will result in reduced traffic lane width on the east side of the road. The proposed sewer alignment is presented in **DWG 002B** as an Option 2 in **Appendix E**. The potential road modifications to the east will impact the existing hydro poles.

With the road design Option 2, it is feasible to increase the capacity of the storm relief sewer along its existing alignment by increasing the width of sewer from 1.45 m to 2.4 m. The hydraulic analysis suggests a new concrete box sewer of 2.4 m X 1.8 m size is feasible.

When compared with the existing conveyance capacity of the storm relief sewer, the proposed 2.4 m X 1.8 m storm sewer will increase the flow conveyance capacity from 4.29 m³/s and 3.55 m³/s to 4.78 m³/s and 4.42 m³/s at the south and north railway underpasses, respectively, for the 2-year storm event and will reduce the pumping rates moderately.

4. Diversion of Flow to New Sherman Avenue Storm Relief Sewer at Princess Street

This measure includes redirecting a portion of Birch Avenue storm flows to Sherman Avenue. A schematic showing the extent of these changes is presented in **Figure 8**. **Table 5** provides a summary of results from the diversion of flows to the new Sherman Avenue storm relief sewer at Princess Street.

Table 5: Storm Sewer Flow Conveyance Improvements

LOCATION	STORM EVENT	PROPOSED (2.4 M X 1.8 M) STORM SEWER (EXISTING STORM UPGRADE UNDER BIRCH AVENUE)			FLOW DIVERSION TO NEW SHERMAN AVENUE STORM RELIEF SERWE		
		Storm Sewer Flow (m ³ /sec)	Overland Flow (m ³ /sec)	Depth (m)	Storm Sewer Flow (m ³ /sec)	Overland Flow (m ³ /sec)	Depth (m)
South Railway Crossing (332)	2-Year	4.78	0.21	0.47	0.72	0.00	0.015
	5-Year	5.82	0.30	0.53	0.97	0.00	0.057
North Railway Crossing (330)	2-Year	4.42	0.67	0.60	2.39	0.026	0.079
	5-Year	4.50	1.74	0.97	2.89	1.57	0.635

This option will convey Birch Avenue flows to the new Sherman Avenue storm relief sewer as presented in **Table 5**. The option is considered hydraulically effective, technically feasible, and will reduce the pumping rates at the underpasses significantly.




Figure 8: Proposed Flow Diversion at Princess Street toward Sherman Avenue

8.3 Pumping Stations

The proposed Birch Avenue improvements include potential upgrades to existing Canadian National Railway (CNR) bridges and changes to road profiles. The lowering of the road profile below lake level will make pumping inevitable. Three options have been examined to address the flooding issues, based on 0.6 m road lowering that best meets the requirement for bridge clearance.

Option 1: Maintain the Existing Storm Relief Sewer

This measure will involve the construction of two separate pumping stations – one at each of the south and north underpasses. The pumps would lift wet weather flow from the Birch Avenue storm relief sewer to a new forcemain. Each pumping station would include a wet well and a forcemain that would connect to the existing trunk storm sewer at Burlington Street East. There is additional capacity downstream of the manhole (MH 39), just before the existing storm outlet at the harbor; therefore, the forcemain would not require a new outlet to the harbor. The forcemain alignment is shown in **DWG 002** in **Appendix C**. The pumping rates for each of the options are provided in **Table 6**.

There is some open-space in City-owned land immediately west of the hydro corridor and north of the south underpass. The land within the Birch Avenue Dog Park, on the west side of Birch Avenue, may be suitable for the construction of a pump station for the south underpass. A geotechnical study will be required to assess the construction feasibility as the dog park is an old landfill site.

At the north underpass, the pumping station is proposed in the northwest quadrant of the Birch Avenue and Burlington Street East intersection. The locations of the pumping stations are provided in **DWG 002** in **Appendix C**. The cost of the pumping stations at the north and south underpasses is provided in **Table 7**.

Option 2: Birch Avenue Storm Sewer Upgrade

The potential upgrades to the existing Birch Avenue storm sewer will reduce the pumping rates by 100 l/s and 200 l/s at the south and north underpasses, respectively. However, this will not reduce the size of the pumping station significantly when compared with Option 1 above. The pumping rates are presented in **Table 6**. The cost of the pumping stations at the north and south underpasses is provided in **Table 7**.

Option 3: New Sherman Avenue Storm Relief Sewer

The option of a new Sherman Avenue storm relief sewer will reduce the pumping requirement significantly. The PCSWMM hydraulic analysis indicated that the diversion of Birch Avenue flows to Sherman Avenue will reduce pumping rates significantly to 26 l/s and 43 l/s for the south and north underpasses, respectively.

With this option, the south and north pumping stations can be combined and constructed in the northwest quadrant of the Birch Avenue and Burlington Street East intersection. This will result in cost savings on property requirements, forcemain installation, pumps, and generator requirements while taking into consideration the operational and maintenance costs. The Option 1 forcemain alignment can be followed to install a gravity pipe from the south wet well to the north wet well. The underground south wet well will still be needed to capture and convey the storm flows. The cost of a pumping station at the north and south underpasses is provided in **Table 7**.

Table 6 presents optional pumping rates for the three alternatives.

Table 6: Optional Pump Rates

OPTION	MITIGATION MEASURE	STORM EVENT	REQUIRED PUMP CAPACITY AT SOUTH RAILWAY CROSSING (#332) (m ³ /sec)	REQUIRED PUMP CAPACITY AT NORTH RAILWAY CROSSING (#330) (m ³ /sec)
1	Existing condition (maintain existing storm relief sewer)	2-Year	0.28	0.78
2	Birch Avenue sewer upgrades (with 2.4 m X 1.8 m storm sewer)	2-Year	0.18	0.58
3	Flow diversion to new Sherman Avenue storm relief sewer	2-Year	0.026	0.043

Note: 5-year storm flows are large and not practical to pump

8.4 Storm Drainage Pumping System

A cast-in-place concrete wet pit/well will be provided. The wet well sizing for each of the options is provided in **Table 8**. Two access hatches will be provided for access inside the pit, complete with access ladders and safety platforms as per OPSD 404.20 requirements. A separate smaller access hatch will be provided for floats access.

Three submersible pumps, one stand-by, will each pump the storm water in the vicinity of the lake at the proposed location. Pumps will be provided with a control panel, floats, and SS guide rails. Discharge piping from each pump will be tied to a common header inside the station. Alarms for pump failure and high water level inside the pit will be sent to a Supervisory Control and Data Acquisition (SCADA) system.

For pump maintenance an appropriate monorail/hoist will be provided.

Refer to sketch SK-M-001 in **Appendix F** for more details on the station equipment layout, sump pit, and pumps for each of the options.

The wet well will be located below grade level and is sized to provide adequate storage of stormwater between pump starts. The surface area of each wet well measure is provided in **Table 8**. **Appendix F** provides details of the wet well configurations.

Heating and Ventilation System

The ventilation rate for the pumping station will be 4 air changes per hour. Fresh air intake louvres and exhaust fans will be interlocked and controlled by a room thermostat to maintain the maximum temperature of 38 deg. C inside the space. Heating will be provided by two electric unit heaters in order to maintain a pumping station temperature above 9 deg. C (adjustable).

The temperature inside the pumping station is to be monitored. Low and high temperature alarms will be connected to the SCADA.

Table 7: Birch Avenue Alternative Remedial Measures to Reduce pumping

Drainage and Stormwater Management Report

Alternative ID	LID Measures	Maintain Existing Storm Relief Sewer	Replace and Upgrade Existing Storm Relief Sewer	New Sewer along Sherman Avenue
Description	Provide underground infiltration chambers from Barton Street East to Burlington Street East to divert Birch Avenue roadway runoff, to detain major overland flows, and infiltrate stormwater.	Maintain existing storm sewer	Replace existing storm sewer with a new storm relief sewer on Birch Avenue from Princess Street to Burlington Street East	Construct a new storm relief sewer along Sherman Avenue. Redirect Birch Avenue flows at Princess Street to new Sherman Avenue storm relief sewer.
Requires Pump	Yes (to drain underpasses)	Yes (to drain underpasses)	Yes (to drain underpasses)	Yes (to drain underpasses)
Outlet to Harbour	Use existing	Use existing	Use existing with upgrade	New
# Railroad Crossings	2 (middle crossing is assumed to be eliminated)	2 (middle crossing is assumed to be eliminated)	2 (middle crossing is assumed to be eliminated)	2 (middle crossing is assumed to be eliminated)
Length of the Proposed Measure	~ 900 m	-	~ 810 m	~ 1 km
Estimated Capital Cost	\$1M (2.5mx1.5m)	-	\$6M (2.4mx1.8m)	\$7M (1.8mx1.8m) includes Princess Diversion
Constructability	Conflicts with Hydro One corridor, 15m of horizontal clearance is required; additional property requirements on west side of Birch Avenue.	-	1. Requires current 1.8m sidewalk to be widened to 2.5m. 2. Modifications at bridges are required, as the current sewer is integral part of bridge structures. 3. Impact to traffic lane width on east side, if bridges are not replaced. 4. Impact on hydro poles on east side of Birch Avenue.	Anticipated crossings: • 10 Sewers(300 to 2250mm) • 13 Water mains (150 to 600mm) • 6 Gas lines (size 32 to 200 I.P) • 3 Bell lines • 6 Hydro ducts
Hydraulic Modeling Results	Will reduce the pumping requirement by 1.26 m ³ /s	Large pumping rates (280lps and 780lps)	It does not provide much relief to pumping at north underpass, as the new sewer will start from Princess Street. Provides 5-year level of service to Birch Avenue (no additional benefit)	Benefits study area but does not provide 5-year level of service due to additional flow from upstream areas.
Secondary Benefit	Reduces pumping at underpasses	-	Reduces pumping at underpasses	Reduces pumping at underpasses, Provides relief to upstream areas. Pumping stations can be combined. Forcemain between south and north pumping stations can be replaced by a gravity sewer.
Pumping Cost	\$5M	\$7M	\$6.5M	\$3.5M
Annual Pump Operating Cost	\$170,000	\$217,500	\$191,000	\$92,000
Size of Pumping Station	12m x 15m (North), 12m x 15m (South)	12m x 15m (South), 15m x 20m (North)	12m x 15m (South), 15m x20m (North)	11m x 8m (North)
Comments	Not Feasible	Feasible	Feasible	Preferred
Preference				

M: Million

General

Piping and valves will be labelled and tagged.

Generator Area, Noise Control and Sizing

The control room will house a diesel generator to provide back-up power in the event of an interruption in power supply. Fresh air will be provided to the room via a louvre and a damper combination (Silex Engine Silenser). Although the station is in an industrial area and involves stormwater pumping, the provision for odour control of the wet well exhaust will be considered in detailed design. The generator sizing is provided in **Appendix G**

Table 8 provides a summary of pumping station details for different options.

Table 8: Pumping Station Details

OPTION	PUMPING STATION	LOCATION	FLOW RATE (lps)	PUMP TYPE	WET WELL	PUMPING STATION SIZE	COMMENT
1	South Pumping Station (332)	Dog Park or existing parking lot adjacent to dog park	280	XFP306M-CB2-60HZ	6 m X 4 m	12 m X 15 m	A geotechnical study will be required to assess the construction feasibility as the dog park is an old landfill site
	North Pumping Station (330)	Northwest quadrant of Birch Avenue and Burlington Street intersection	780	XFP 400M-CH2-60 HZ	6 m X 6 m	15 m X 20 m	
2	South Pumping Station (332)	Dog park or existing parking lot adjacent to dog park	180	XFP-300-J-CH2-60HZ-	6 m X 4 m	12 m X 15 m	A geotechnical study will be required to assess the construction feasibility as the dog park is an old landfill site
	North Pumping Station (330)	Northwest quadrant of Birch Avenue and Burlington Street intersection	580	XFP 351M-CH3 60 HZ	6 m X 6 m	15 m X 20 m	
3	South Pumping Station (332)	Pumping station not required	26	-	4 m X 4 m	-	-
	North Pumping Station (330)	Northwest quadrant of Birch Avenue and Burlington Street intersection	43	XFP151E-CB2-60HZ	8 m X 4 m	11 m X 8 m	Combined pumping flow will be 69 lps

8.5 Dewatering Costs

Based on preliminary estimates, the dewatering costs may vary from \$50,000 to \$65,000 depending on the location. It is recommended that the City budgets \$55,000 for dewatering costs. However, the actual cost will be determined and budgeted for during detailed design. Details of the dewatering costs are provided in **Appendix H**.

9 Conclusions and Recommendations


This report documents the drainage and stormwater management aspects associated with the existing and proposed flooding conditions at the Birch Avenue underpasses. It describes the existing and proposed drainage conditions within the study limits and outlines the proposed drainage and SWM Plan to manage flooding along the Birch Avenue. The findings of this study are summarized as follows:

- The Birch Avenue study area is located on a primary overland flow route with large external drainage areas contributing flows to the storm trunk relief sewer.
- Within the Birch Avenue roadway corridor, runoff from minor storm events is conveyed by the existing storm relief sewer. Due to the limited flow conveyance capacity of the existing storm relief sewer, all major storm flows are conveyed by road.
- Currently there are three low/sag points located along the Birch Avenue at the railway crossing locations. These low points and adjacent areas currently experience flooding.
- The existing railway bridge located south of Brant Street (331) is proposed to be removed and the low point located at this crossing location will be eliminated to provide a positive roadway drainage.
- The storm relief sewer inverts range from 74.29 m at Burlington Street East, 75.0 m just north of the south railway underpass, 75.20 m at Princess Street and 76.29 m at Barton Street East. Summer average water level of Lake Ontario is approximately 75.0 m which has adverse hydraulic effects on the existing storm relief sewer flow conveyance.
- The proposal to lower the road at the south (332) and north (330) underpasses, to achieve required bridge clearances, will result in additional ponding at the bridge crossing locations and pumping will be inevitable to eliminate the flooding at these locations.
- The preferred alternative is to lower the road between 0.3 m to 0.6 m to achieve the desired bridge clearance under the north and south underpasses.
- Pumping is proposed at the south (332) and north (330) underpasses to lift excess wet weather flows from the Birch Avenue storm relief sewer. The 5-year storm event is relatively large and not practical to pump.
- The pumped water will be conveyed through a proposed force main. The last leg of storm relief sewer at Burlington Street East has enough capacity to discharge the pumped flow directly in the harbour.
- Three pumping options were evaluated. The option of flow diversion to a new Sherman Avenue storm relief line was considered most economical and preferred option. This preferred option achieves 2-year level of service.
- A geotechnical investigation should be undertaken to evaluate and confirm the subsurface conditions in the area.

Appendix A

EXISTING CONDITION DRAWING

BIRCH AVE LAYOUT



No.	REVISIONS	INITIAL	DATE	REFERENCE MATERIAL
1	Revisions			
				Road Plan : 97-H-14, 96-H-11, 88-H-1, 68-H-33, 68-H-108
				Sewer Plans : 88-S-6, 10-S-53, B-130-S3, P-23-S1, 78-S-56
				Water Plans : 88-W-16
				Misc. Plans: 62R-14437, 05-M-14
				Geodetic Bench Mark Index No. 4-06 Elevation: 82.438

D/C IN ACCORDANCE WITH ASCE STANDARD 38-02
 All utilities depicted are as shown unless otherwise noted.
 Information derived from existing records.
 Information obtained from field survey combined with information.
 Information obtained in field and indicates horizontal position of subsurface utility.
 Precise horizontal and vertical location of utilities shown on this plan are obtained by exposure and measurement in millimetres unless otherwise noted.




Project Manager (Design)
 NAME
 Manager of Design

BIRCH AVENUE
 Existing Conditions
 DWG NO-001

➔ OVERLAND FLOW

Appendix B

TYPICAL CROSS SECTIONS





TYPICAL CROSS-SECTION
NTS

Appendix C


PROPOSED CONDITION DRAWING

BIRCH AVE LAYOUT
LID MEASURES :OPTION 1
PUMPING STATION LOCATIONS : FOR OPTION1, OPTION2 & OPTIONS3



No.	REVISIONS	INITIAL	DATE	REFERENCE MATERIAL
1	No Revisions			
				Road Plan : 97-H-14, 96-H-11, 88-H-1, 68-H-33, 68-H-100
				Sewer Plans : 88-S-6, 10-S-53, B-130-S3, P-23-S1, 78-S-56
				Water Plans : 88-W-15
				Misc. Plans: 62R-14437, 05-M-14
				Geodetic Bench Mark Index No. 4-06 Elevation=82.438

D/C IN ACCORDANCE WITH ASCE STANDARD 38-02
 All Utilities depicted are at unless otherwise noted.
 Information derived from existing records
 Information obtained from field survey combined with information
 Information obtained in field and indicates horizontal position of subsurface utility
 Precise horizontal and vertical location of utilities on the plan are obtained by exposure and measurement millimetres unless otherwise noted



Project Manager (Design)
 NAME
 Manager of Design

BIRCH AVENUE
 Proposed Conditions
 DWG NO-002A

Appendix D

THE SCS TYPE II E HOUR HYETOGRAPH


**TABLE 5.1
6 HOUR SCS DISTRIBUTION DESIGN STORM HYETOGRAPHS
MOUNT HOPE**

Time Step (min)	Rainfall Intensity (mm/hr)					
	2	5	10	25	50	100
10	1.59	2.26	2.70	3.26	3.68	4.09
20	1.59	2.26	2.70	3.26	3.68	4.09
30	1.59	2.26	2.70	3.26	3.68	4.09
40	2.38	3.39	4.06	4.90	5.51	6.14
50	2.38	3.39	4.06	4.90	5.51	6.14
60	2.38	3.39	4.06	4.90	5.51	6.14
70	2.38	3.39	4.06	4.90	5.51	6.14
80	2.38	3.39	4.06	4.90	5.51	6.14
90	2.38	3.39	4.06	4.90	5.51	6.14
100	3.97	5.65	6.76	8.16	9.19	10.23
110	3.97	5.65	6.76	8.16	9.19	10.23
120	3.97	5.65	6.76	8.16	9.19	10.23
130	4.76	6.78	8.11	9.79	11.03	12.28
140	4.76	6.78	8.11	9.79	11.03	12.28
150	4.76	6.78	8.11	9.79	11.03	12.28
160	23.82	33.90	40.56	48.96	55.14	61.38
170	42.88	61.02	73.01	88.13	99.25	110.48
180	61.93	88.14	105.46	127.30	143.36	159.59
190	8.73	12.43	14.87	17.95	20.22	22.51
200	8.73	12.43	14.87	17.95	20.22	22.51
210	8.73	12.43	14.87	17.95	20.22	22.51
220	3.97	5.65	6.76	8.16	9.19	10.23
230	3.97	5.65	6.76	8.16	9.19	10.23
240	3.97	5.65	6.76	8.16	9.19	10.23
250	3.18	4.52	5.41	6.53	7.35	8.18
260	3.18	4.52	5.41	6.53	7.35	8.18
270	3.18	4.52	5.41	6.53	7.35	8.18
280	2.38	3.39	4.06	4.90	5.51	6.14
290	2.38	3.39	4.06	4.90	5.51	6.14
300	2.38	3.39	4.06	4.90	5.51	6.14
310	1.59	2.26	2.70	3.26	3.68	4.09
320	1.59	2.26	2.70	3.26	3.68	4.09
330	1.59	2.26	2.70	3.26	3.68	4.09
340	1.59	2.26	2.70	3.26	3.68	4.09
350	1.59	2.26	2.70	3.26	3.68	4.09
360	1.59	2.26	2.70	3.26	3.68	4.09

Appendix E

PROPOSED CONDITIONS DRAWING (OPTION 2 &3)


**BIRCH AVE LAYOUT
OPTION 2 & 3**



No.	REVISIONS	INITIAL	DATE	REFERENCE MATERIAL
1	No Revisions			

REFERENCE MATERIAL
Road Plan : 97-H-14, 96-H-11, 88-H-1, 68-H-33, 68-H-100
Sewer Plans : 88-S-6, 10-S-53, B-130-S3, P-23-S1, 78-S-56
Water Plans : 88-W-15
Misc. Plans 62R-14437, 05-M-14
Geodetic Bench Mark Index No. 4-06 Elevation=82.438

D/C IN ACCORDANCE WITH ASCE STANDARD 38-02
 All utilities depicted are at unless otherwise noted.
 (1) information derived from existing records
 (2) information obtained from field survey combined with
 (3) information obtained in field and indicates horizontal position of subsurface utility
 (4) precise horizontal and vertical location of utility as obtained by exposure and measurement millimetres unless otherwise noted



Project Manager (Design)
 NAME
 Manager of Design

Hamilton
 Public Works
 Department

BIRCH AVENUE
 Proposed Conditions
 DWG NO-002B




Appendix F

PUMP STATION EQUIPMENT LAYOUTS


SOUTH PUMPING STATION : OPTION 1 & 2

LEGEND:

- 1 WET PIT
- 2 SUBMERSIBLE PUMP AND REMOVABLE ACCESS HATCH (TYP.)
- 3 MAINTENANCE ACCESS HATCH
- 4 PUMPS LANDING AREA
- 5 3 TON PUMPS HOIST
- 6 PUMPS DISCHARGE HEADER
- 7 UNDERGROUND PUMPED STORM LINE TO LAKE
- 8 PUMPS CONTROL PANEL
- 9 INSULATED PREFABRICATED BUILDING WITH SLOPED ROOF
- 10 EXHAUST FAN
- 11 ELECTRIC UNIT HEATER
- 12 FRESH AIR INTAKE LOUVRE
- 13 MCC
- 14 TRANSFER SWITCH
- 15 HYDRO METERING PANEL
- 16 EMERGENCY GENERATOR C/W ENCLOSURE
- 17 TRANSFORMER
- 18 CONCRETE PAD



PLAN VIEW




SUMP PIT ELEVATION

	IBI GROUP	Date	Issued For	Rev.
	100-175 Galaxy Boulevard Toronto ON M9W 0C9 Canada tel 416 679 1930 fax 416 675 4620 ibigroup.com	2019-10-10	EA STUDY	A
	Client CITY OF HAMILTON ONTARIO			
	Project ENVIRONMENTAL ASSESSMENT STUDY			
This drawing has been prepared solely for the use of and there are no representations of any kind made by IBI Group to any party with whom IBI Group has not entered into a contract.		Drawing Title PROPOSED OPTION STORM PUMPING STATION AT BRIDGE 332		Project No. 121767
				Drawing No. SK-M-001


NORTH PUMPING STATION : OPTION 1 & 2

LEGEND:

- 1 WET PIT
- 2 SUBMERSIBLE PUMP AND REMOVABLE ACCESS HATCH (TYP.)
- 3 MAINTENANCE ACCESS HATCH
- 4 PUMPS LANDING AREA
- 5 3 TON PUMPS HOIST
- 6 PUMPS DISCHARGE HEADER
- 7 UNDERGROUND PUMPED STORM LINE TO LAKE
- 8 PUMPS CONTROL PANEL
- 9 INSULATED PREFABRICATED BUILDING WITH SLOPED ROOF
- 10 EXHAUST FAN
- 11 ELECTRIC UNIT HEATER
- 12 FRESH AIR INTAKE LOUVRE
- 13 MCC
- 14 TRANSFER SWITCH
- 15 HYDRO METERING PANEL
- 16 EMERGENCY GENERATOR C/W ENCLOSURE
- 17 TRANSFORMER
- 18 CONCRETE PAD





PLAN VIEW



SUMP PIT ELEVATION

	IBI GROUP	Date	Issued For	Rev.
	100-175 Galaxy Boulevard Toronto ON M9W 0C9 Canada tel 416 679 1930 fax 416 675 4620 ibigroup.com	2019-10-10	EA STUDY	A
	Client CITY OF HAMILTON ONTARIO			
	Project ENVIRONMENTAL ASSESSMENT STUDY			
This drawing has been prepared solely for the use of and there are no representations of any kind made by IBI Group to any party with whom IBI Group has not entered into a contract.		Drawing Title PROPOSED OPTION STORM PUMPING STATION AT BRIDGE 330		Project No. 121767
				Drawing No. SK-M-002

PUMPING STATION : OPTION 3
(COMBINED NORTH & SOUTH)



 <p>IBI GROUP 100-175 Galaxy Boulevard Toronto ON M9W 0C9 Canada tel 416 679 1930 fax 416 675 4620 ibigroup.com</p>	Date	Issued For	Rev.
	2019-10-10	EA STUDY	A
	Client CITY OF HAMILTON ONTARIO		
	Project ENVIRONMENTAL ASSESSMENT STUDY		
	Drawing Title		Project No.
PROPOSED OPTION		121767	
STORM PUMPING STATION		Drawing No.	
AT BRIDGE 330		SK-M-002	
<p>This drawing has been prepared solely for the use of and there are no representations of any kind made by IBI Group to any party with whom IBI Group has not entered into a contract.</p>			

PUMP DESIGN

No: M-02.3087 - 04 2

Dat/Nam.: 02.06.2016 / K. Srb

Cad Code: M_023087

Technical changes reserved
Änderungen vorbehalten
Sous réserve de modifications

XFP 306M-CB2


Dimension sheet PE6 WET WELL Installation

Maßblatt PE6 Nassinstallation

Plan d'encombrement PE6 installation submersible



Type Typ Type	Type Typ Type	Weight Gewicht Poids		H		Size
		MK		(mm)	(inch)	
50Hz	60Hz	(~kg)	(~lb)			
PE 1320/4-M		2150	4741	2252	88.7	A
PE 1600/4-M	PE 1850/4-M-60	2255	4972			
PE 2000/4-M	PE 2200/4-M-60	2595	5722	2412	95.0	B
PE 2500/4-M	PE 2800/4-M-60	2700	5954			
	PE 1250/6-M-60	2195	4840	2252	88.7	A
	PE 1500/6-M-60	2275	5016			
	PE 1850/6-M-60	2570	5667	2412	95.0	B
	PE 2200/6-M-60	2750	6064	2512	98.9	C




Weight: Includes pump, slider bracket and 10m cable
Gewicht: Beinhaltet Pumpe, Halterung und 10m Kabel
Poids: Pompe, coulisseau et 10m de câble




For different cable length see IOM, chapter 1.5
Für abweichende Kabellänge siehe EBA, Kapitel 1.5
Pour des longueurs supérieures, voir la section 1.5 du manuel

For hex.-woodscrew 0,4*2,8 plug 0,5 DIA
Für Skt.-Holzschr. 10*70 Dübel Ø12mm
Pour vis à bois hexagonale 10*70 trou de 12mm


Installation instructions "pedestal" 1 597 2507
Installationsanweisung "Fußstück" 1 597 2507
Instruction d'installation du "pied d'assise" 1 597 2507



Guide tube 2" EN 10255-M
Führungsrohr 2" EN 10255-M




DN300, DIN EN 1092-2, PN10
12" ANSI B16.1 CLASS 125



[mm
[inch]

MK = Mit Kühlmantel
With cooling jacket
Avec enveloppe de refroidissement


XFP 306M-CB2 60 HZ



Operating data specification Flow 3730 US g.p.m. Efficiency 74,8 % NPSH 10,5 ft Temperature 68 °F No. of pumps 2		Power input 156 hp Head 119 ft Rated power 150 hp Fluid Water Nature of system Single pumps as parallel circuit	
Pump data Type XFP 306M-CB2 60 HZ Series XFP PE4-PE7 N° of vanes 2 Free passage 4,13 x 4,72 inch Discharge flange DN300 Moment of inertia 41,1 lb ft ²		Make SULZER Impeller Contrablock Plus impeller Impeller size 18 2/3inch Suction flange DN300 Type of installation wet well vertical installation 2"	
Motor data Rated voltage 600 V Rated power P2 201 hp Number of poles 6 Power factor 0,811 Starting current 1380 A Starting torque 2410 lbf ft Insulation class H(140)		Frequency 60 Hz Nominal Speed 1180 rpm Efficiency 95,6 % Rated current 186 A Rated torque 892 lbf ft Degree of protection IP 68 No. starts per hour 10	

Curve number	Pump performance curves		SULZER
Reference curve XFP 306M-CB2 60 HZ	XFP 306M-CB2 60 HZ		


			Discharge DN300	Frequency 60 Hz
Density 62,32 lb/ft ³	Viscosity 1,082E-5 ft ² /s	Testnorm ISO9906:2012, HI 11.6/14.6 Gr2B		Rated speed 1193 rpm
Flow 3730 US g.p.m	Head 119 ft	Shaft power 150 hp	Power input 156 hp	Rated power P2 201 hp
			Hydraulic efficiency 74,8 %	NPSH 10,5 ft



Impeller size 18 2/3 inch	N° of vanes 2	Impeller Contrablock Plus impeller	Solid size 4,13 x 4,72 inch	Revision
------------------------------	------------------	---------------------------------------	--------------------------------	----------

Curve number	Pump performance curves	SULZER
Reference curve XFP 306M-CB2 60 HZ	XFP 306M-CB2 60 HZ	

				Discharge DN300	Frequency 60 Hz
Density 62,32 lb/ft ³	Viscosity 1,082E-5 ft ² /s	Testnorm ISO9906:2012, HI 11.6/14.6 Gr2B		Rated speed 1193 rpm	Date 2019-10-09
Flow 7459 US g.p.m.	Head 119 ft	Shaft power 150 hp	Power input 156 hp	Rated power P2 201 hp	Hydraulic efficiency 74,8 %
NPSH 10,5 ft					



Impeller size 18 2/3 inch	N° of vanes 2	Impeller Contrablock Plus impeller	Solid size 4,13 x 4,72 inch	Revision
------------------------------	------------------	---------------------------------------	--------------------------------	----------

Frequency
60 Hz


PE6

Motor performance curve

PE1500/6



Rated power 201 hp	Service factor 1	Nominal Speed 1180 rpm	Number of poles 6	Rated voltage 600 V	Date 2019-10-09
-----------------------	---------------------	---------------------------	----------------------	------------------------	--------------------




Symbol	No load	25 %	50 %	75 %	100 %	125 %
P_2 / hp	0	50,29	100,6	150,9	201,2	251,4
P_1 / hp	3,486	54,43	104,9	157,5	210,3	264,3
η / %	0	92,39	95,91	95,76	95,63	95,15
n / rpm	1200	1198	1195	1192	1190	1188
$\cos \varphi$	0,02975	0,4152	0,6331	0,7491	0,8093	0,8402
I / A	84,08	94,06	118,8	150,9	186,5	225,7
s / %	0	0,2083	0,4167	0,625	0,8333	1,042
M / lbf ft	0	220,6	442,1	664,5	887,8	1112

Tolerance according to VDE 0530 T1 12.84 for rated power

Starting current 1380 A	Starting torque 2410 lbf ft	Moment of inertia 90,4 lb ft ²	No. starts per hour 10
----------------------------	--------------------------------	--	---------------------------


XFP 300J-CH2 60 HZ



Operating data specification Flow 215,8 l/s Efficiency 77,8 % NPSH 8,04 ft Temperature 68 °F No. of pumps 1		Power input 33,9 hp Head 28,7 ft Rated power 31 hp Fluid Water Nature of system Single head pump	
Pump data Type XFP 300J-CH2 60 HZ Series XFP PE4-PE7 N° of vanes 2 Free passage 110 x 127 mm Discharge flange DN300 Moment of inertia		Make SULZER Impeller 2-vane channel impeller Impeller size 368 mm Suction flange DN300 Type of installation wet well vertical installation 2"	
Motor data Rated voltage 480 V Rated power P2 33,5 hp Number of poles 8 power factor 0,741 Starting current 221 A Starting torque 378 lbf ft Insulation class H(140)		Frequency 60 Hz Nominal Speed 884 rpm Efficiency 91,4 % Rated current 43,4 A Rated torque 199 lbf ft Degree of protection IP 68 No. starts per hour 10	

Curve number	Pump performance curves XFP 300J-CH2 60 HZ	SULZER
Reference curve XFP 300J-CH2 60 HZ		

			Discharge DN300	Frequency 60 Hz
Density 62,32 lb/ft ³	Viscosity 1,082E-5 ft ² /s	Testnorm ISO9906:2012,HI 11.6/14.6 Gr2B	Rated speed 885,6 rpm	Date 2019-11-07
Flow 215,8 l/s	Head 28,7 ft	Shaft power 31 hp	Power input 33,9 hp	Rated power P2 33,5 hp
			Hydraulic efficiency 77,8 %	NPSH 8,04 ft



Impeller size 368 mm	N° of vanes 2	Impeller 2-vane channel impeller	Solid size 110 x 127 mm	Revision
-------------------------	------------------	-------------------------------------	----------------------------	----------

Sulzer reserves the right to change any data and dimensions without prior notice and can not be held responsible for the use of information contained in this software.

Spaix® 4, Version 4.3.12 - 2019/08/29 (Build 267)
data version Sept 2019

Frequency
60 Hz

PE4

Motor performance curve



PE 250/8

Rated power
33,5 hp


Service factor
1,3

Nominal Speed
884 rpm

Number of poles
8

Rated voltage
480 V

Date
2019-11-07




Symbol	No load	25 %	50 %	75 %	100 %	125 %
P ₂ / hp	0	8,381	16,76	25,14	33,53	41,91
P ₁ / hp	1,471	9,934	18,59	27,52	36,67	46,16
η / %	0	84,37	90,15	91,36	91,43	90,78
n / rpm	899	895,8	892,4	888,6	884,2	880
cos φ	0,05995	0,3493	0,5505	0,6755	0,7407	0,7671
I / A	22	25,51	30,3	36,54	44,4	53,98
s / %	0,1063	0,4687	0,8404	1,271	1,754	2,227
M / lbf ft	0	49,14	98,66	148,6	199,1	250,1

Tolerance according to VDE 0530 T1 12.84 for rated power

Starting current 221 A	Starting torque 378 lbf ft	Moment of inertia 13,6 lb ft ²	No. starts per hour 10
---------------------------	-------------------------------	--	---------------------------


XFP 400M-CH2 60 HZ



Operating data specification Flow 838,4 l/s Efficiency 69,1 % NPSH 24,3 ft Temperature 68 °F No. of pumps 1		Power input 207 hp Head 41,8 ft Rated power 198 hp Fluid Water Nature of system Single head pump	
Pump data Type XFP 400M-CH2 60 HZ Series XFP PE4-PE7 N° of vanes 2 Free passage 180 x 150 mm Discharge flange DN400 Moment of inertia 38,7 lb ft²		Make SULZER Impeller 2-vane channel impeller Impeller size 473 mm Suction flange DN400 Type of installation wet well vertical installation 2"	
Motor data Rated voltage 480 V Rated power P2 248 hp Number of poles 6 power factor 0,838 Starting current 2080 A Starting torque 2860 lbf ft Insulation class H(140)		Frequency 60 Hz Nominal Speed 1180 rpm Efficiency 95,8 % Rated current 277 A Rated torque 1100 lbf ft Degree of protection IP 68 No. starts per hour 10	

Curve number	Pump performance curves XFP 400M-CH2 60 HZ	SULZER
Reference curve XFP 400M-CH2 60 HZ		

			Discharge DN400	Frequency 60 Hz
Density 62,32 lb/ft ³	Viscosity 1,082E-5 ft ² /s	Testnorm ISO9906:2012,HI 11.6/14.6 Gr2B	Rated speed 1193 rpm	Date 2019-11-07
Flow 838,4 l/s	Head 41,8 ft	Shaft power 198 hp	Power input 207 hp	Rated power P2 248 hp
			Hydraulic efficiency 69,1 %	NPSH 24,3 ft



Impeller size 473 mm	N° of vanes 2	Impeller 2-vane channel impeller	Solid size 180 x 150 mm	Revision
-------------------------	------------------	-------------------------------------	----------------------------	----------

Frequency
60 Hz


PE6

Motor performance curve



PE1850/6

Rated power 248 hp	Service factor 1	Nominal Speed 1180 rpm	Number of poles 6	Rated voltage 480 V	Date 2019-11-07
-----------------------	---------------------	---------------------------	----------------------	------------------------	--------------------




Symbol	No load	25 %	50 %	75 %	100 %	125 %
P_2 / hp	0	62,02	124	186,1	248,1	310,1
P_1 / hp	4,007	67,24	129,8	194,4	259,1	326,9
η / %	0	92,24	95,56	95,73	95,74	94,88
n / rpm	1199	1197	1195	1193	1191	1189
$\cos \varphi$	0,03353	0,4854	0,7053	0,7996	0,8389	0,858
I / A	107,2	124,3	165,1	218	277	341,7
s / %	0,08333	0,25	0,4167	0,5833	0,75	0,9167
M / lbf ft	0	272,2	545,2	819,2	1094	1370

Tolerance according to VDE 0530 T1 12.84 for rated power

Starting current 2080 A	Starting torque 2860 lbf ft	Moment of inertia 207 lb ft ²	No. starts per hour 10
----------------------------	--------------------------------	---	---------------------------


XFP 351M-CH3 60 HZ



Operating data specification Flow 873,1 l/s Efficiency 53,3 % NPSH 67 ft Temperature 68 °F No. of pumps 1		Power input 306 hp Head 45,3 ft Rated power 294 hp Fluid Water Nature of system Single head pump	
Pump data Type XFP 351M-CH3 60 HZ Series XFP PE4-PE7 N° of vanes 3 Free passage 150 x 110 mm Discharge flange DN350 Moment of inertia 37,7 lb ft²		Make SULZER Impeller 3-vane channel impeller Impeller size 490 mm Suction flange DN350 Type of installation wet well vertical installation 2"	
Motor data Rated voltage 480 V Rated power P2 295 hp Number of poles 6 power factor 0,819 Starting current 2900 A Starting torque 3920 lbf ft Insulation class H(140)		Frequency 60 Hz Nominal Speed 1190 rpm Efficiency 95,8 % Rated current 337 A Rated torque 1310 lbf ft Degree of protection IP 68 No. starts per hour 10	

Curve number	Pump performance curves XFP 351M-CH3 60 HZ	SULZER
Reference curve XFP 351M-CH3 60 HZ		

					Discharge DN350	Frequency 60 Hz
Density 62,32 lb/ft ³	Viscosity 1,082E-5 ft ² /s	Testnorm ISO9906:2012,HI 11.6/14.6 Gr2B			Rated speed 1193 rpm	Date 2019-11-07
Flow 873,1 l/s	Head 45,3 ft	Shaft power 294 hp	Power input 306 hp	Rated power P2 295 hp	Hydraulic efficiency 53,3 %	NPSH 67 ft



Impeller size 490 mm	N° of vanes 3	Impeller 3-vane channel impeller	Solid size 150 x 110 mm	Revision
-------------------------	------------------	-------------------------------------	----------------------------	----------

Sulzer reserves the right to change any data and dimensions without prior notice and can not be held responsible for the use of information contained in this software.

spaix® 4, Version 4.3.12 - 2019/08/29 (Build 267)
data version sept 2019

Frequency
60 Hz


PE6

Motor performance curve



PE2200/6

Rated power 295 hp	Service factor 1	Nominal Speed 1190 rpm	Number of poles 6	Rated voltage 480 V	Date 2019-11-07
-----------------------	---------------------	---------------------------	----------------------	------------------------	--------------------




Symbol	No load	25 %	50 %	75 %	100 %	125 %
P ₂ / hp	0	73,76	147,5	221,3	295	368,8
P ₁ / hp	5,671	80,5	154,3	231,1	307,7	385,8
η / %	0	91,63	95,61	95,74	95,87	95,6
n / rpm	1199	1198	1196	1194	1193	1192
cos φ	0,03444	0,4348	0,6574	0,7686	0,8189	0,8429
I / A	147,7	166,1	210,5	269,7	337	410,5
s / %	0,08333	0,2083	0,3333	0,4583	0,5833	0,7083
M / lbf ft	0	323,5	647,8	972,9	1299	1626

Tolerance according to VDE 0530 T1 12.84 for rated power

Starting current 2900 A	Starting torque 3920 lbf ft	Moment of inertia 247 lb ft ²	No. starts per hour 10
----------------------------	--------------------------------	---	---------------------------

XFP151E CB2 60HZ (wet pit)



Operating data specification Flow 80,11 l/s Efficiency 69,7 % NPSH 18,5 ft Temperature 20 °C No. of pumps 1		Power input 10 kW Head 27 ft Rated power 9,26 kW Fluid Water Nature of system Single head pump	
Pump data Type XFP151E CB2 60HZ (wet pit) Series XFP PE1-PE3 N° of vanes 2 Free passage 76,2 mm Discharge flange DN150 Moment of inertia 0,0236 kg m ²		Make SULZER Impeller Contrabloc impeller, 2 vane Impeller size 230 mm Suction flange DN150 Type of installation Wet Well installation with pedestal	
Motor data Rated voltage 460 V Rated power P2 10,5 kW Number of poles 4 power factor 0,81 Starting current 106 A Starting torque 118 Nm Insulation class H		Frequency 60 Hz Nominal Speed 1750 1/min Efficiency 92,4 % Rated current 17,7 A Rated torque 57,2 Nm Degree of protection IP 68 No. starts per hour 15	

Frequency
60 Hz


PE2

Motor performance curve



PE105/4-E-60HZ

Rated power 10,5 kW	Service factor 1,3	Nominal Speed 1750 1/min	Number of poles 4	Rated voltage 460 V	Date 2019-11-08
------------------------	-----------------------	-----------------------------	----------------------	------------------------	--------------------



Symbol	No load	25 %	50 %	75 %	100 %	125 %
P_2 / kW	0	2,625	5,25	7,875	10,5	
P_1 / kW	0,2553	3,069	5,774	8,508	11,36	
η / %	0	85,52	90,93	92,56	92,4	
n / 1/min	1800	1790	1779	1767	1754	
$\cos \phi$	0,03956	0,4049	0,6324	0,7537	0,8057	
I / A	8,1	9,514	11,46	14,17	17,7	
s / %	0,0007998	0,5572	1,163	1,819	2,56	
M / Nm	0	14	28,18	42,55	57,17	

Tolerance according to VDE 0530 T1 12.84 for rated power

Starting current 106 A	Starting torque 118 Nm	Moment of inertia 0,0449 kg m ²	No. starts per hour 15
---------------------------	---------------------------	---	---------------------------

Appendix G

GENERATOR SIZING

Generator Sizing Details:

Pump Flow Litre/sec.	Pump Type	Generator Sizing		Cost
		HP	Alternator	
235	SULZER XFP306M-CB260HZ-235lps	250HP	600kW	\$155K
381	SULZER XFP301M-CH260HZ_381lps	400HP	800kW	\$380K
780	XFP_400M-CH2__60_HZ 780lps 20ft head	350HP	800kW	\$250K
180	XFP_300_J_CH2_60HZ_180lps 20ft	50HP	125kW	\$70K
580	XFP_351M-CH3__60_HZ_580 20ft	400HP	800kW	\$380K
26	XFP_80C_CB1_60HZ_(wet_pit) 26lps 20ft	-	-	-
43	XFP150G_CP_60HZ_(wet_pit_dry_pit) 43lps 6m 20ft	-	-	-
69	XFP151E_CB2_60HZ_(wet_pit) 69lps 20ft	20HP	50kW	\$45K

Appendix H

DEWATERING COSTS

