



**TECHNICAL STANDARDS
and SAFETY AUTHORITY**

345 Carlingview Drive
Toronto, Ontario M9W 6N9
Toll free 1-877-682-8772
www.tssa.org

Inspection Report

Work Order # 14215704

Inspection Report # 10153175

Inspection Address: 777 Highway 8 Stoney Creek ON L8E 5J4 Canada	Reference Number(s): 64423	Inspection Completion Date: Aug 12, 2024
	Device Type: Freight Platform Lift-B	Equipment Type: ED Elevator
Customer Name and Address: CITY OF HAMILTON 28 JAMES ST N 5TH FLOOR HAMILTON ON L8R 2K1 Canada	Task Type: ED Periodic Inspection	
	The facility/equipment is inspected in accordance with Ontario's Technical Standards & Safety Act and the appropriate regulations and codes. When an Inspector's order is issued, time limits for compliance reflect the severity of the violation and serve to avoid disruption of service.	

Inspection report delivered by email fmcpcomp@hamilton.ca

INSPECTION NOTES

Inspection Order(s) are issued pursuant to my authority under section 21. (1) of the Technical Standards and Safety Act, 2000.

Where inspection orders are issued, TSSA will perform a follow-up inspection to confirm compliance. The responsible party is expected to make all the necessary corrections within the compliance time specified.

Where safety tasks are issued, TSSA will not perform a follow-up inspection to confirm compliance. The responsible party is expected to make all the necessary corrections within the compliance time specified. Safety tasks may be subject to a TSSA audit inspection and/or the responsible party may be required to confirm compliance to obtain your authorization/license.

INSPECTION ORDER(S) and/or SAFETY TASK(S) ISSUED TO: CITY OF HAMILTON

EMAIL RECIPIENTS brad.merritt@hamilton.ca tssa.swontario@ca.schindler.com , stephen.varga@hamilton.ca

No.	Safety Tasks	Issued Date	Compliance Date
1.	The overdue scheduled maintenance task for overspeed valve setting (CAD 8.6.5.13) shall be performed and the log book signed to confirm compliance.	Aug 12, 2024	Nov 10, 2024
2.	The overdue scheduled maintenance task for gland packings and seals (CAD 8.6.5.5) shall be performed and the log book signed to confirm compliance.	Aug 12, 2024	Nov 10, 2024
3.	The overdue category 1 [annual] periodic task for relief valve	Aug 12, 2024	Nov 10, 2024

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.
(Note: This is not an invoice)

Putting Public Safety First



**TECHNICAL STANDARDS
and SAFETY AUTHORITY**

345 Carlingview Drive
Toronto, Ontario M9W 6N9
Toll free 1-877-682-8772
www.tssa.org

Inspection Report

Work Order # 14215704

Inspection Report # 10153175

	verification of setting and system pressure test(CAD 8.6.5.14.1) shall be performed and the log book signed to confirm compliance.		
4.	The overdue category 1 [annual] periodic task for hydraulic cylinders and pressure testing (CAD 8.6.5.14.2) shall be performed and the log book signed to confirm compliance.	Aug 12, 2024	Nov 10, 2024
5.	The overdue category 1 [annual] periodic task for hydraulic elevator additional tests (CAD 8.6.5.14.3) shall be performed and the log book signed to confirm compliance. The overdue category 1 periodic task for normal terminal stopping devices (CAD 8.6.5.14.3 (a)) shall be performed and the log book signed to confirm compliance.	Aug 12, 2024	Nov 10, 2024
6.	The overdue category 1 [annual] periodic task for flexible hose and fitting assemblies (CAD 8.6.5.14.4) shall be performed and the log book signed to confirm compliance.	Aug 12, 2024	Nov 10, 2024

This report is issued under the *Technical Standards and Safety Authority Act, 2000, s. 17(1)*

17. (1) An inspector may conduct an inspection and may, as part of that inspection, enter and inspect at any reasonable time the lands and premises where any of the things, parts of the things or classes of things to which this Act, the regulations or a Minister's order apply are used, operated, installed, made, manufactured, repaired, renovated or offered for sale for the purpose of,
(a) ensuring compliance with this Act, the regulations or Minister's order;
(b) ensuring that an authorization holder remains entitled to the authorization; or
(c) determining whether a hazardous condition exists. 2006, c. 34, s. 25 (5)

Customer Signature & Position / Date:		Inspector Name: Ben Sharp	Inspector Contact Number: +1 647-530-8649
Report Received By:	Customer Contact Number:	Inspector Email: BSharp@tssa.org	

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.
(Note: This is not an invoice)

Putting Public Safety First