



**TECHNICAL STANDARDS  
and SAFETY AUTHORITY**

345 Carlingview Drive  
Toronto, Ontario M9W 6N9  
Toll free 1-877-682-8772  
www.tssa.org

**Inspection Report**

**Work Order # 14212707**

**Inspection Report # 10150505**

Inspection Address: 876 CANNON ST E HAMILTON ON L8L 0C6 Canada	Reference Number(s): 64788390	Inspection Completion Date: Feb 2, 2024
	Device Type: Passenger Elevator	Equipment Type: ED Elevator
Customer Name and Address: CITY OF HAMILTON 28 JAMES ST N 5TH FLOOR HAMILTON ON L8R 2K1 Canada	Task Type: ED Follow-up Inspection - Periodic	
	<b>The facility/equipment is inspected in accordance with Ontario's Technical Standards &amp; Safety Act and the appropriate regulations and codes. When an Inspector's order is issued, time limits for compliance reflect the severity of the violation and serve to avoid disruption of service.</b>	

**Inspection report delivered by email**

**INSPECTION NOTES**

Inspection Order(s) are issued pursuant to my authority under section 21. (1) of the Technical Standards and Safety Act, 2000.

Where inspection orders are issued, TSSA will perform a follow-up inspection to confirm compliance. The responsible party is expected to make all the necessary corrections within the compliance time specified.

Where safety tasks are issued, TSSA will not perform a follow-up inspection to confirm compliance. The responsible party is expected to make all the necessary corrections within the compliance time specified. Safety tasks may be subject to a TSSA audit inspection and/or the responsible party may be required to confirm compliance to obtain your authorization/license.

TSSA has completed an inspection of this device and has issued Safety Task(s). TSSA will not perform a follow-up inspection to confirm compliance. The responsible party is expected to make all the necessary corrections within the compliance time specified.

**INSPECTION ORDER(S) and/or SAFETY TASK(S) ISSUED TO: CITY OF HAMILTON**

**EMAIL RECIPIENTS** Sam.Ciardullo@hamilton.ca tssa.swontario@ca.schindler.com

No.	Safety Tasks	Issued Date	Compliance Date
1.	The overdue category 5 [Five year] Periodic Task for maintenance of the overspeed valve (CAD 8.6.5.16.5) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
2.	The overdue category 5 [Five year] Periodic Task for power operation of doors (CAD 8.6.4.20.7) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.  
(Note: This is not an invoice)

**Putting Public Safety First**



TECHNICAL STANDARDS  
and SAFETY AUTHORITY

345 Carlingview Drive  
Toronto, Ontario M9W 6N9  
Toll free 1-877-682-8772  
www.tssa.org

Inspection Report

Work Order # 14212707

Inspection Report # 10150505

3.	The overdue scheduled maintenance task for overspeed valve setting (CAD 8.6.5.13) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
4.	The owner shall display the TSSA issued installation number in the elevator (tag or engraved).	Jan 19, 2024	Apr 17, 2024
5.	Post the current elevating device license in a conspicuous location in the car, or at an alternate location if permission has been sought from the director.  Wrong license in the car.	Jan 19, 2024	Apr 17, 2024
6.	The overdue category 1 [annual] periodic task for normal and final terminal stopping devices (CAD 8.6.4.19.5) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
7.	The overdue category 1 [annual] periodic task for firefighter's emergency operation (CAD 8.6.4.19.6) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
8.	The overdue category 1 [annual] periodic task for standby or emergency power and emergency lowering operation (CAD 8.6.4.19.7) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
9.	The overdue category 1 [annual] periodic task for power operation of door system (CAD 8.6.4.19.8) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
10.	The overdue category 1 [annual] periodic task for emergency communications (CAD 8.6.4.19.15) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
11.	The overdue category 1 [annual] periodic task for relief valve verification of setting and system pressure test(CAD 8.6.5.14.1) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
12.	The overdue category 1 [annual] periodic task for hydraulic cylinders and pressure testing (CAD 8.6.5.14.2) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.  
(Note: This is not an invoice)

Putting Public Safety First



**TECHNICAL STANDARDS  
and SAFETY AUTHORITY**

345 Carlingview Drive  
Toronto, Ontario M9W 6N9  
Toll free 1-877-682-8772  
www.tssa.org

**Inspection Report**

**Work Order # 14212707**

**Inspection Report # 10150505**

13.	The overdue category 1 [annual] periodic task for hydraulic elevator additional tests (CAD 8.6.5.14.3) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024
14.	The overdue category 1 [annual] periodic task for pressure switch (CAD 8.6.5.14.5) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Apr 17, 2024

No.	Resolved Inspection order(s) or Safety Task(s)	Issued Date	Status
1.	The overdue category 1 [annual] periodic task for means to restrict hoistway or car door opening (CAD 8.6.4.19.16) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Resolved
2.	The overdue category 1 [annual] periodic task for car door reopening device(s) (CAD 8.6.4.19.18) shall be performed and the log book signed to confirm compliance.	Jan 19, 2024	Resolved

**This report is issued under the *Technical Standards and Safety Authority Act, 2000, s. 17(1)***

17. (1) An inspector may conduct an inspection and may, as part of that inspection, enter and inspect at any reasonable time the lands and premises where any of the things, parts of the things or classes of things to which this Act, the regulations or a Minister's order apply are used, operated, installed, made, manufactured, repaired, renovated or offered for sale for the purpose of,  
 (a) ensuring compliance with this Act, the regulations or Minister's order;  
 (b) ensuring that an authorization holder remains entitled to the authorization; or  
 (c) determining whether a hazardous condition exists. 2006, c. 34, s. 25 (5)

<b>Customer Signature &amp; Position / Date:</b>		<b>Inspector Name:</b> William Gilmet	<b>Inspector Contact Number:</b> +1 647-459-9665
<b>Report Received By:</b>	<b>Customer Contact Number:</b>	<b>Inspector Email:</b> wgilmet@tssa.org	

As a not-for-profit regulatory authority, TSSA operates on a cost recovery basis.  
(Note: This is not an invoice)

**Putting Public Safety First**